



Customer TTZ100688

Test facility
Turbo-Tec EPS 815

Customer number

Job number 1

Telephone

Fax

Remark

Test user

Operator CR1

Type number 0445110047	--	Type designation CRI 1	Revision date 12.10.2006	Compensation
Manufacturer Bosch	Component CRI	Type 1 MV	Control point 	Temperature 40 °C

Complaint

Problem

Remark

	Injector A	Injector B	Injector C	Injector D	Injector E	Injector F
Serial number			2312271628330			
Date of manuf.						
Repair ID						
Repair res.						
Leak test						
Classification	---	---	---	---	---	---
			A0			

# 5	Warm up				Flow meas.	°C
	Warm up Testbench					= 40
n /min	°C	p MPa	t μs	p kPa	s	
→ ← 1000	→ ← 40.0	→ ← 130.0	→ ← 1000	→ ← 10.0	----	
250	↓↑ 1.0	↓↑ 10.0	n/min ----	20	----	
= 1000	= 39.0	= 130.0			= 26	

# 6	Stabilizing				Flow meas.	
	Stabilizing Injector					
n /min	°C	p MPa	t μs	p kPa	s	
→ ← 1000	→ ← 40.0	→ ← 130.0	→ ← 1000	→ ← 10.0	----	
250	↓↑ 1.0	↓↑ 1.0	n/min ----	20	180	
= 1000	= 40.1	= 130.0			= 180	



Type number	Type designation	Revision date	Compensation
0445110047	CRI 1	12.10.2006	X
Manufacturer	Component	Control point	Temperature
Bosch	CRI		40 °C

Serial number	Injector A	Injector B	Injector C	Injector D	Injector E	Injector F
			2312271628330			
Date of manuf.						

# 7	Conditioning	Flow meas.				
	Conditioning for VL point					
n /min	°C	p MPa	t μs	p kPa	s	
→ ← 1000	→ ← 40.0	→ ← 130.0	→ ← 1000	10.0	----	
250	↓↑ 1.0	↓↑ 1.0	n/min ----	20	70	
= 1000	= 40.1	= 130.2			= 70	

# 8	VL	Flow meas.				
	Measure point VL					
n /min	°C	p MPa	t μs	p kPa	s	
→ ← 1000	→ ← 40.0	→ ← 130.0	→ ← 1000	10.0	----	
250	↓↑ 1.0	↓↑ 1.0	n/min ----	20	----	
= 1000	= 40.1	= 130.0			= 20	

mm³/H
→|← 58.7
↓↑ 4.0
/c= 60.3

mm³/H
→|← 39.0
↓↑ 22.0
/c= 39.5

# 9	Conditioning	Flow meas.				
	Conditioning for EM point					
n /min	°C	p MPa	t μs	p kPa	s	
→ ← 1000	→ ← 40.0	→ ← 60.00	→ ← 600	10.0	----	
250	↓↑ 1.0	↓↑ 1.0	n/min ----	20	70	
= 1000	= 40.1	= 60.0			= 70	

# 10	EM	Flow meas.				
	Measure point EM					
n /min	°C	p MPa	t μs	p kPa	s	
→ ← 1000	→ ← 40.0	→ ← 60.00	→ ← 600	10.0	----	
250	↓↑ 1.0	↓↑ 1.0	n/min ----	20	----	
= 1000	= 40.1	= 60.0			= 20	

mm³/H
→|← 15.8



Type number	Type designation	Revision date	Compensation
0445110047	CRI 1	12.10.2006	
Manufacturer	Component	Control point	Temperature
Bosch	CRI		40 °C

Serial number	Injector A	Injector B	Injector C	Injector D	Injector E	Injector F
			2312271628330			
Date of manuf.						

3.9
 = 15.2

11 Conditioning
 Conditioning for LL point

Flow meas.

n	/min		°C	p	MPa
	1000		40.0		30.00
	250		1.0		1.0
=	1000	=	40.0	=	30.0

t	μs
	575

p	kPa	s
	10.0	----
	20	70
=		70

12 LL
 Measure point LL

Flow meas.

n	/min		°C	p	MPa
	1000		40.0		30.00
	250		1.0		1.0
=	1000	=	40.0	=	30.0

t	μs
	575

p	kPa	s
	10.0	----
	20	----
=		20

mm³/H
 3.9
 1.9
 = 3.1

13 Conditioning
 Conditioning for VE point

Flow meas.

n	/min		°C	p	MPa
	1000		40.0		60.00
	250		1.0		1.0
=	1000	=	39.9	=	60.0

t	μs
	230

p	kPa	s
	10.0	----
	20	70
=		70

14 VE
 Measure point VE

Flow meas.

n	/min		°C	p	MPa
	1000		40.0		60.00
	250		1.0		1.0
=	1000	=	39.9	=	60.0

t	μs
	230

p	kPa	s
	10.0	----
	20	----
=		20

mm³/H
 1.4



Type number	Type designation	Revision date	Compensation
0445110047	CRI 1	12.10.2006	
Manufacturer	Component	Control point	Temperature
Bosch	CRI		40 °C

Serial number	Injector A	Injector B	Injector C	Injector D	Injector E	Injector F
			2312271628330			
Date of manuf.						

 = 2.1

15 Conditioning
 Conditioning for VE point

Flow meas.

n	/min		°C	p	MPa
	1000		40.0		80.00
	250		1.0		1.0
=	1000	=	40.0	=	80.0

t	μs
	160

n/min	----

p	kPa	s
	10.0	----
	20	70
=		70

16 VE
 Measure point VE

Flow meas.

n	/min		°C	p	MPa
	1000		40.0		80.00
	250		1.0		1.0
=	1000	=	40.0	=	80.0

t	μs
	160

n/min	----

p	kPa	s
	10.0	----
	20	----
=		20

\bar{Q} / mm³/H
 1.5
 1.2
 = 1.9